

Radial Crush Test for E3X 1431 kcmil ACSS Overhead Conductor

NEETRAC Project: 24-151

Final Report


May 2026




NEETRAC

National Electric Energy Testing,
Research, and Applications Center

Requested by: Idaho National Labs

Principal Investigator/Reviewed by: 
Joe Goldenburg, P.E.

Report written by: 
Ian Brown, E.I.T.

NOTICE

The information contained herein is, to our knowledge, accurate and reliable at the date of publication.

Neither GTRC nor The Georgia Institute of Technology nor NEETRAC shall be responsible for any injury to or death of persons or damage to or destruction of property or for any other loss, damage or injury of any kind whatsoever resulting from the use of the project results and/or data.

GTRC, GIT and NEETRAC disclaim any and all warranties, both express and implied, with respect to analysis or research or results contained in this report.

It is the user's responsibility to conduct the necessary assessments in order to satisfy themselves as to the suitability of the products or recommendations for the user's particular purpose.

No statement herein shall be construed as an endorsement of any product, process or provider.

Copyright of this report shall reside with GTRC.

Sponsor(s) are assigned the non-transferrable rights listed below:

1. Sponsor has title to the evaluation data contained herein. If there is more than one sponsor, they have joint title to the evaluation data.
2. Sponsor(s) may conduct their own analysis of the data, while representing such analysis as their own.
3. Sponsor(s) may use Copyrighted material in its entirety within their organizations (listed below).
4. Sponsor(s) may provide Copyrighted material in its unabridged entirety without any transfer of rights to external entities for that entity's internal use only as indicated in the NOTE below.
5. Sponsor(s) may place Copyrighted material in its entirety in the public domain (literature packet, internet, etc.) provided that the context of such publication may not be construed as an endorsement of any product, process or provider by GTRC, GIT, or NEETRAC.

Sponsors may not distribute or publish abstracted or excerpted material from this document without the prior written permission of NEETRAC.

For the avoidance of doubt, sponsor(s), in the context of this assignment of rights, shall mean the entities listed below:

Battelle Energy Alliance (Idaho National Labs)

NOTE: This Copyrighted material is intended solely for the use of the project sponsor(s) in the manner listed above. If you are not an intended recipient you are hereby notified that any dissemination, distribution or copying of this Copyrighted material is prohibited. If you have received this Copyrighted material in error, please immediately notify the provider and permanently delete this Copyrighted material and any copies.

Table of Contents

1.0 EXECUTIVE SUMMARY4

2.0 TEST SAMPLES4

3.0 PROCEDURE.....5

 3.1 Crush5

 3.2 Evaluation and Tensile Test6

4.0 RESULTS7

5.0 CONCLUSION.....9

6.0 EQUIPMENT9

7.0 STANDARDS9

List of Figures

Figure 1: Conductor Section (L) and Strand Samples (R)4

Figure 2: Crushing setup shown while crushing is in progress.....5

Figure 3: Sample installed in UTM before testing.....6

Figure 4: Very light flattening shown on a 150 lb/in sample with marks indicating the span where the bottom platen made contact7

Figure 5: Example of marks on inner aluminum strands from upper layer7

Figure 6: Tensile Test Results.....8

Figure 7: Typical Force-Deflection Curve9

Radial Crush Test for E3X 1431 kcmil ACSS Overhead Conductor NEETRAC Project 24-151

1.0 EXECUTIVE SUMMARY

Idaho National Labs requested that NEETRAC perform crush testing on Prysmian E3X 1431 kcmil ACSS conductor in compliance with Cigre Technical Bulletin 426 and ASTM B803. The purpose of this testing was to evaluate the conductor's integrity and susceptibility to "hidden" damage caused by relatively light crushing loads (in the hundreds of pounds, such as being run over by a utility truck), which the conductor may experience in the field.

2.0 TEST SAMPLES

In preparation for this test, 15 three-foot conductor sections were acquired, as shown in Figure 1. Various mechanical loads were applied to each. After load application each section was disassembled, and a single strand was harvested from each core layer. The harvested strands were subjected to tensile testing, also shown in Figure 1.




Figure 1: Conductor Section (L) and Strand Samples (R)

3.0 PROCEDURE

3.1 Crush

Each of the 15 conductor sections were separated into five groups, which allowed for three replicates of each group's mechanical load application. These groups were labeled as and subjected to particular crushing loads as follows:

1. 75 lb/in
2. 100 lb/in
3. 125 lb/in
4. 150 lb/in
5. Reference samples (no crush load was applied)

Crush loads were applied to the conductor sections by NEETRAC's universal testing machine (UTM) between a compression platen on the machine's crosshead and a 4" long rectangular crush platen on the bottom, as shown in Figure 2. The 4" length of the bottom platen determined the crushing load that each of the triplet groups were subjected to based upon the loads labeled above. For example, the 75 lb/in group was subjected to a crush load of 300 lbs (75 lb/in x 4 in = 300 lbs).

Each conductor section was crushed once by itself in its approximate center, as shown in Figure 2. For each section, the crush load was applied and held for 10 minutes before being released. However, three reference samples were not subjected to crushing at all, as they were control samples.




Figure 2: Crushing setup shown while crushing is in progress

3.2 Evaluation and Tensile Test

After application of mechanical crush loads, each of the sections were broken down as described in section 2.0. They were straightened as much as possible before an ultimate tensile strength test was performed on each of the samples, as shown in Figure 3. Compliance for tensile testing of these strands is dictated by ASTM B803.



Figure 3: Sample installed in UTM before testing

4.0 RESULTS

After crushing, minimal flattening was noticed on some of the outer aluminum strands of some conductor sections, as shown in Figure 4. However, no significant damage was noted beyond this. The inner aluminum strand layers did show signs of rubbing from the aluminum layers on top of them, as seen in Figure 5. Based on similar observations of the reference samples, these marks were not due to crushing.



Figure 4: Very light flattening shown on a 150 lb/in sample with marks indicating the span where the bottom platen made contact



Figure 5: Example of marks on inner aluminum strands from upper layer

For a radial crush test such as this, Cigre TB 426 only requires testing for residual core strand strength along with noting damage to strands. Therefore, tensile testing only evaluated the strands' ultimate tensile strength and not its elongation. Per ASTM B803, the minimum ultimate tensile stress of the strands is 230 ksi. In testing, all samples passed this requirement. The box and whisker plot below in Figure 6 shows the tensile testing results. Figure 7 shows a sample's typical stress-deflection curve.




Figure 6: Tensile Test Results




Figure 7: Typical Force-Deflection Curve

5.0 CONCLUSION

After being subjected to crush loading, all samples passed the requirement set for tensile strength by ASTM B803. All crush testing was done in compliance with Cigre TB 426.

6.0 EQUIPMENT

Tinius-Olsen UTM CQ-0013

7.0 STANDARDS

Cigre Technical Bulletin 426, "Guide for Qualifying High Temperature Conductors for Use on Overhead Transmission Lines"

ASTM B803/B803M-22 Standard Specification for High-Strength Zinc-5% Aluminum-Mischmetal Alloy-Coated Steel Core Wire for Use in Overhead Electrical Conductors