Alexander Abboud Jake Gentle Jacob Lehmer Tyler Phillips Brandon Starks

# Using Dynamic Line Ratings for Wind Farm Gen-Tie Line Considerations

**Clean Power 2021 Virtual Event** 

June 7-10, 2021



# Background

- IEEE/CIGRE standards provide a base for overhead transmission line ratings
  - Steady State Ampacity industry standard for Static Ratings using conservative environmental assumptions
- Measurement of many types of sensors provide a possibility to provide more capacity as a time varying capability
  - Direct sensors of line temperature, tension, or sag provide critical, location specific information.
  - Require complex transformation to determine line ampacity rating
  - Are direct measurements sensors placed at key location(s)?
  - Testing and careful calibration of sensors required
- Wide Area Weather-based DLR can provide a calculation of the moment-to-moment steady state rating
  - Definition of weather station proximity to spans is critical One weather-station based calculation can not approximate a long line or a line with complex terrain.

# **State of the Industry**

- The US produces 4.1 trillion Kilowatt-hours of electricity per year
- Distributed by 500 Power Companies
- 160,000 Miles (~260,000Km) of High Voltage (>100kV) transmission lines in the U.S. known as "the grid."
- Challenge is getting it to cities, factories, military bases in the right amounts when needed
- Power utilities operate transmission lines based on static ratings, which set a conservative limit on the amount of current the lines can safely carry without overheating
- **Dynamic line ratings** can allow for additional capacity on existing lines



- Without accurately measuring the environmental conditions and their effects, lines can be critically underutilized.
- Without conservative and accurate forecasts of capacity utilities can NOT plan and effectively use the capacity.

# **Technical Approach**

**Computational Fluid Dynamics Informed Weather Based Dynamic Line Rating** 



Use CFD to calculate relative speed and direction from measured (or forecasted) locations to spans



# **CFD Process**

For each area:

- Identify bounds for simulation and section divisions based on approximated memory usage
- Create elevation/roughness layer
- Get weather station data/locations and structure midpoints
- Run wind simulations
- Extract data at all midpoint locations
- Create lookup tables scaled on the historical weather station data
  - difference in speed/direction from measured location to transmission lien location
- Lookup tables go into GLASS for historical/real-time/forecasted rating
  - Assume self-similar boundary profiles of wind speed



# **Line Rating Equations**

- Heat balance of convective cooling, radiative heat loss, joule heating solar heating  $\sqrt{q_c + q_r q_s}$
- In order to solve the steady state equation, we need:



# **DLR Forecasting Suggested Timeline**



*Visualization:* How does weather data compare to static assumptions? How does prevailing wind compare to transmission line direction?





# **Forecasting Example**

- Computation time frame delay occurs with obtaining updated regional forecast results
- Use ANN or persistence in region <2 hours in the future</li>
- Beyond this, use regional forecasts with decreasing temporal updates based on how far in the future the forecast is needed



# What is the HRRR?

- NOAA High-Resolution Rapid Refresh Model
  - Data is publicly available from NOMADS, some archived data available publicly







### http://www.nco.ncep.noaa.gov/pmb/products/hrrr/

### Used in Idaho study

- Extract 3 km grid spacing over Idaho
- Output variables of temperature, wind speed, wind direction, and solar flux at 10 m height at WS locations



# **Accuracy with HRRR Forecasts**

HRRR forecasts are more accurate than persistence for lead times 2.5 – 16.5 hours

Persistence is better than the HRRR at the 30-minute lead time

Similar errors at 1.5 hour lead time (except wind direction)

Over time the error of the HRRR does not significantly increase – similar accuracy in ampacity should be expected whether using HRRR for 3 hours in future or 18 hours in future



# Wind Farm near Idaho Falls

- 78 Turbines total turbines
  - Collector 1: Turbines 1-38,
  - Collector 2: Turbines 39-78
- 115 m hub height, 170 m blade, 5.8 MW max
- 225 MW from collector to collector and 450 MW collector to transmission



# **Gen Tie Lines**

Squares show midpoints, circles show HRRR locations

Collector 1-to-collector 2 225 MW capacity



Collector 2-to-transmission 450 MW capacity



# **Updated Turbines**

- Triangles show Turbines, circles are weather stations
- Use power curve for 5.8 MW turbines, CFD calculates difference in wind speed from measurements to turbines and feeds into power curve







Roughness layer shows major features

Highway MFC blip Lava field

# **Computational Fluid Dynamics**

• Results shown at line height and turbine height



### **Weather Station Data / Wind**

### **HRRR Forecast**

### **Observational**



# Weather Station Data / Solar and Temperature

### **HRRR Forecast**





### **Observational**





# Weather Station Data / QA Tests

- QA Tests
  - Wind speeds greater than 75 m/s.
  - Wind speed changes less than
    0.5 m/s per hour.
  - Constant wind directions with changing speeds.
  - Wind speed changes greater than 20 m/s.
  - Temperature changes greater than 8°C per hour.
- Crop out "bad" weather data from analysis

### **QA Test Error**



Most likely due to long periods of low wind currents.

# Wind Power Generation Data for 2020



## Wind Generation Data

• Resample weather station data for analysis to match HRRR frequency



### Wind Generation Data

- Gen-tie line conductor
  - Baseline selection of Bluejay and Partridge ACSR for 450/225MW
  - Selected so that generation does not exceed static rating



# **Gen Tie-line Dynamic Power Capacity and Error**

- Dynamic power capacity of baseline conductors
- RMSE between models

$$RMSE = \sqrt{\frac{\sum_{i=1}^{N} (P_{HRRR} - P_{WS})^2}{N}}$$





	Conductor	HRRR3		HRRR36		
	Conductor	RSME	%RSME	RSME	%RSME	
Gen Tie Line 1	Ibis	55.0	15.2	55.0	15.4	
	Partridge	54.2	15.6	43.2	15.8	
	Pigeon	30.4	16.1	30.5	16.3	
Gen Tie Line 2	Blueiay	153.0	19.1	151.8	19.3	
	Snowbird	145.8	19.2	144.7	19.4	
	Drake	127.4	19.4	126.5	19.6	
	Gull	112.1	19.6	111.3	19.8	
	Ibis	82.9	20.0	82.4	20.2	

# **Concurrent Cooling**

- Difference in dynamic power capacity and wind generation
- Protentional for additional generation





Gen Tie-Line 1

500

# **Concurrent Cooling Results**

- Partridge has additional 31 MW capacity 99% of the time
- Bluejay has additional 233 MW capacity 99% of the time
  - Drake has 116 MW capacity 99% of the time
  - Gull has 48 MW capacity 99% but goes below base generation requiring small curtailment

	G 1 4	Percent of Time					
	Conductor	80%	90 %	95%	99%	100%	
1 je:	Ibis	175	149	131	105	68	
en ] ine	Partridge	89	66	51	31	3	
L G	Pigeon	-4	-21	-32	-49	-65	
5	Blueiay	417	354	307	233	153	
Line	Snowbird	377	316	270	199	122	
[ie-]	Drake	280	221	180	116	45	
en T	Gull	196	141	104	48	-19	
Ŭ	Ibis	32	-12	-40	-83	-138	







- DLR was used to rate a gen-tie line for a proposed wind farm
- This approach showed ~50%+ additional capacity available on gen-tie line using DLR
  - Or line can be downsized for capital cost reduction
- When considering forecasting, some accounting for error needs to occur
  - Day ahead and near-term forecasts have very similar error
  - In this particular region 15-20% of ampacity

# **Acknowledgements**

 This research was performed by Idaho National Laboratory with support from NorthRenew Energy and funding from the U.S. Department of Energy Wind Energy Technologies Office. INL is operated by Battelle Energy Alliance under contract No. DE-AC07-05ID14517.

# Idaho National Laboratory

WIND INTEGRATION R&D Concurrent Cooling, Dynamic Line Rating

Jake P. Gentle – jake.gentle@inl.gov

ABORATORY