

# Sapienza Contribution to WGAMA International Standard Problem-52: PKL experiment on Multiple SG U-tube rupture

2025 IRUG Technical Seminar,  
Idaho National Laboratory, Idaho Falls, Idaho  
28 July – 01 August 2025



Dipartimento di Ingegneria Astronautica,  
Elettrica ed Energetica (DIAEE)  
Nuclear Engineering Research Group (NERG)





Giorgio Mongiardini  
Cristiano Ciurluini  
Fabio Giannetti  
Gianfranco Caruso



# PKL Facility: Overview

- Operated by Framatome GmbH in Erlangen, Germany.
- Replicates PWR primary system with reduced scale (1:145 in volume), preserving TH characteristics (pressure, temperature, flow distribution).
- Highly instrumented for data collection (temperature, pressure, flow rates, swelling levels).
- **Purpose:** experimentally study transient & accident conditions: LOCAs, Loss of RHR during shutdown; Secondary-side cooldown transients, etc.




- 1 Reactor Pressure Vessel
- 2 Steam Generators
- 3 Reactor Coolant Pump
- 4 Pressurizer
- 5 Accumulators





## PKL III J5.1 run 2: Test Boundary Conditions






## PKL III J5.1 run 2: Test Boundary Conditions (cont'd)

### Power Source Terms:

- Core Power drops according to Decay Heat.
- PRZ Heaters active @ nominal power (8 kW).
- UH and UP Heaters active (3.1 & 1.3 kW).
- SGs Bypass Heaters active up to SGs dry-out (16.5 kW per component)






- Primary System Depressurization (**PSD**) starts 1000 s after SoT.
- **SGs sec. steam discharge system** manually operated up to 9200 s after SoT.



## PKL III J5.1 run 2: Test Boundary Conditions (cont'd)





### Accident Management (cont'd):

- HPIS on Core Exit Temperature (CET)  $> 350^\circ\text{C}$ ;
- 4 CL Accumulators (ACC) triggered when  $p_{prim} < 23.6$  bar. HL ACCs not available.
- LPIS triggered when  $p_{prim} < 12.4$  bar.



# PKL III J5.1 run 2: Time Windows



| TWs | Timing [s] | Description                       | Main Phenomena                                                                                                                   |
|-----|------------|-----------------------------------|----------------------------------------------------------------------------------------------------------------------------------|
| TW1 | 0 – 1000   | <u>SoT</u> to <u>Start of PSD</u> | <ul style="list-style-type: none"> <li>P2S mass discharge through breaks;</li> <li>SGs sec. side SRVs mass discharge.</li> </ul> |





## PKL III J5.1 run 2: Time Windows (cont'd)



| TWs | Timing [s]  | Description                                                       | Main Phenomena                                                                                                                                                                                                                        |
|-----|-------------|-------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| TW2 | 1000 – 9240 | <u>Start of PSD</u><br>to<br><u>SGs Sec. Side final isolation</u> | <ul style="list-style-type: none"> <li>NC interruption;</li> <li>P/S pressure equalization;</li> <li>Break MF inversion (from P2S to S2P);</li> <li>PRZ PORV mass discharge;</li> <li>SGs sec. side SRVs pressure control.</li> </ul> |





## PKL III J5.1 run 2: Time Windows (cont'd)



| TWs | Timing [s]   | Description                                        | Main Phenomena                                                                                                                                         |
|-----|--------------|----------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|
| TW3 | 9240 – 14700 | <u>SGs Sec. Side final isolation to SGs dryout</u> | <ul style="list-style-type: none"> <li>S2P mass discharge through breaks;</li> <li>PRZ PORV mass discharge;</li> <li>SGs gradually emptied.</li> </ul> |





## PKL III J5.1 run 2: Time Windows (cont'd)



| TWs | Timing [s]    | Description                                               | Main Phenomena                                                                                                                                             |
|-----|---------------|-----------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|
| TW4 | 14700 – 17340 | <u>SGs dryout</u><br>to<br><u>Start of HPSI Injection</u> | <ul style="list-style-type: none"> <li>PRZ PORV mass discharge;</li> <li>PS mass reduction;</li> <li>Core dryout;</li> <li>CET &amp; PCT peaks.</li> </ul> |






## PKL III J5.1 run 2: Time Windows (cont'd)

| TWs | Timing [s]    | Description                                        | Main Phenomena                                                                                                                                                                                                                      |
|-----|---------------|----------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| TW5 | 17340 – 27500 | <u>Start of HPSI Injection</u><br>To<br><u>EoT</u> | <ul style="list-style-type: none"> <li>PRZ PORV mass discharge;</li> <li>HPSI injection → LS Clearing; Core quenching;</li> <li>Acc. Injection → LS Filling; CET subcooled;</li> <li>Solid PRZ;</li> <li>LPSI injection.</li> </ul> |





# Nodalization






## Nodalization Features

- Each loop (of 4) modelled with a dedicated batch of components.
- DC tubes within RPV (of 2) simulated separately.
- Core region modelled with 2 Eq. Pipes, i.e., active core & bypass.
- 10 Control Volumes (CVs) for the Core Active Region (0.39 m mesh length).
- 48 CVs for the U-tubes active length (0.35 m average mesh length).

## Special Models

|                           |                  |
|---------------------------|------------------|
| Chocked flow              | Ransom-Trapp     |
| SG separator/dryer models | R5 default model |
| PRZ specific models       | NO               |
| CCFL model                | NO               |



## Input @ a glance

|             |      |
|-------------|------|
| Hyd. Vol.   | 1203 |
| Jun N°      | 1225 |
| HSs         | 999  |
| Temp Points | 7976 |



## Simulation results: Initial Conditions

| System              | Parameter         | Unit           | Exp.                | Open                    |
|---------------------|-------------------|----------------|---------------------|-------------------------|
| Prim.<br>Power Bal. | Core              | kW             | 880                 | 881.4                   |
|                     | PRZ Heaters       | kW             | 8.0                 | 8.0                     |
|                     | USP Heaters       | kW             | 1.24                | 1.37                    |
|                     | RPV Heaters       | kW             | <b>Defective</b>    | 2.7                     |
| Primary<br>System   | Pressure          | bar            | 47.0                | 47.0                    |
|                     | Core Inlet Temp.  | °C             | 254                 | 255.6                   |
|                     | CET               | °C             | 261 (Sat.)          | 261.1 (Sat.)            |
|                     | Inventory         | m <sup>3</sup> | 1890                | 1827                    |
|                     | PRZ Inv.          | m <sup>3</sup> | 78                  | 67                      |
|                     | MassFlows (L1-L4) | kg/s           | 2.8/2.7/<br>2.8/2.9 | 2.60/2.60/<br>2.66/2.84 |
|                     | PRZ Level         | m              | 2.34                | 2.39                    |
|                     | RPV Level         | m              | 7.35                | 7.30                    |
|                     | Core Level        | m              | 6.00                | 5.64                    |




## Simulation results: Initial Conditions (cont'd)

| System         | Parameter              | Unit           | Exp.                    | Open                       |
|----------------|------------------------|----------------|-------------------------|----------------------------|
| Sec.<br>System | Exch. Power (SG1-SG4)  | kW             | -                       | 217.6/216.9<br>223.2/225.7 |
|                | Bypass Heat. (SG1-SG4) | kW             | 17.8/17.7/<br>18.0/17.8 | 17.5/17.5<br>17.5/17.5     |
|                | Pressure (SG1-SG4)     | bar            | 43                      | 43.0/43.0/<br>43.0/43.0    |
|                | Inventory (SG1-SG4)    | m <sup>3</sup> | 735/740/<br>743/730     | 734/734/<br>734/734        |
|                | Level (SG1-SG4)        | m              | 12.2/12.3<br>12.3/12.2  | 12.1/12.1/<br>12.1/12.1    |
| Parameter      | PKL section            | Unit           | Ref. Data               | Open                       |
| Heat<br>Losses | RPV                    | kW             | 51.5                    | 49.5                       |
|                | LOOPs                  | kW             | 24.3                    | 27.0                       |
|                | MCP (Cooling)          | kW             | -20.3                   | -20.3                      |
|                | PRZ and surge line     | kW             | 10.0                    | 11.7                       |
|                | SGs (vessel) SS        | kW             | 71.4                    | 75.2                       |



## PKL III J5.1 run 2: Results




**Deviations between numerical results and experimental data:**

- Oscillations at the edge of TW3/TW4
- Misalignment in TW5




## PKL III J5.1 run 2: Results






### Ransom-Trapp model:

- Seems to overestimate the discharged mass flow when core dryout occurs (steam flow @ the vapor)
- Does not properly simulate the subcooled water flow in TW5, producing the pressure misalignment






# PKL III J5.1 run 2: Results



**This oscillations @ the break  
produce the PS pressure oscillations**




## PKL III J5.1 run 2: Results




**Still under investigation (higher heat losses?)**

**Only post-processing issue. 'Tempg' is plotted in this figure, while CET is subcooled @ the end of TW5.**






# PKL III J5.1 run 2: Results







**Slight underestimation. Possible causes:**

- Power distribution between inner/middle/outer zones
- Pin thermal conductivity values









## PKL III J5.1 run 2: Results





# PKL III J5.1 run 2: Results





## PKL III J5.1 run 2: Conclusions

- RELAP5-3D<sup>©</sup> predictions of the selected PKL test are in good agreement with the experimental data.
- RELAP-3D<sup>©</sup> demonstrated to be able to well simulate complex 2D phenomena: choked flow through the PRZ PORV, primary-secondary systems pressure equalization, loop seal clearing, core dryout and quenching, etc.
- Only some minor aspects have still to be investigated (core inlet temperature in TW5, etc.);
- Sensitivity analysis is planned about some selected parameters (pin th. cond., heat losses, etc.)
- PKL III J5.1 run 1 simulation is planned for the prosecution of the activity.



*Thanks for your attention*

---



*Any questions?*

---