



UNIVERSITÀ DI PISA

UNIVERSITÀ DI PISA



N.I.N.E.

www.nineeng.com

Nuclear and Industrial Engineering

**SCCRED: a Supporting Tool for V&V and Uncertainty Evaluation
of Best-Estimate System Codes for Licensing Applications**

A. Petruzzi (UNIFI-NINE), F. D'Auria (UNIFI)


Presented by M.Lanfredini (UNIFI-NINE)

- Introduction and objective
- Computational tools for best estimate safety analysis
- The SCCRED methodology
 - Reference Data Sets
 - Qualification Report
 - Engineering Handbook
- SCCRED: a supporting tool for V&V of BEPU methodologies
 - UMAE and CIAU methodologies
- Conclusions

- Availability of Experimental Data might not be enough:
 - Information spread on several reports
 - Different quality level and format of the documentation
 - Need to explain and clarify the information
 - Contradictions exist
- Preserving the Experimental Data shall be a MUST
- Qualified experimental database is envisaged by IAEA (SRS 23)
- Need for a **STANDARD** for fully exploit the experimental data and generate a **CONSOLIDATED Calculated and Reference Experimental Database (SCCRED)**
- Use of SCCRED for V&V of:
 - Computational tools
 - Uncertainty Evaluation

- SCCRED bases:
 - Coherent and logic flow path
 - Iterative procedure
 - ✓ **multiple** feedback
 - ✓ **independent** review
 - Different level of analysts


High Quality




X<Y<Z: indicate three levels of analysts group

Achievements

- Development of a methodology for collecting, organizing, using and preserving an exhaustive set of geometrical data and experimental results
 - Exhaustive consolidated information is a standardized format
 - Traceability
 - Documentation of the decisions taken in case of lack of data or in presence of contradictory information
 - Creation of databases (experimental data & associated calculations) for BE code assessment and validation of UM
- Development of **Reference Data Set** documents for developing input decks
- Setting up standard procedures for using the collected data and qualify the code calculations (**Qualification Report**)
- Development of a standard report (**Engineering Handbook**) containing a full description of how the database has been converted into an input data deck for a specific computer code (support to verification)


- **Consistent, consolidated and standardized** set of relevant data of the facility and the tests
 - Check the quality of the data
 - Resolve possible contradiction review
 - ✓ dispersed and not exhaustive information
 - ✓ Duration of experimental campaign
 - Explain information on geometry and TH properties
 - Perform and independent review
 - Application of quality assurance procedures
- The RDS are **Code-independent** → suitable for input development and qualification and for UM development and validation
- Two different types of RDS
 - RDS-Facility: one RDS for each facility in a “reference status”
 - RDS-test: one for each experiment performed in the facility




- The RDS-Facility is related with the design in a “**reference status**” of a facility and consists of the following **standard** sections
 - Layout of the facility
 - Collection of geometrical data (length, volumes, areas, elevations) for each subsystem and component of the facility
 - Collection of specific data for complex component (pumps, valves, heaters, etc...)
 - Identification of geometrical discontinuities and evaluation of pressure loss coefficients (normal operation)
 - Material properties
 - Measurement system
 - Nominal heat losses
 - Nuclear data (if available)
- “**Reference status**” corresponds to a geometrical and hardware configuration of the facility at a certain time

- Subdivision in **code-independent** modules

- 100 – Primary circuit: broken loop
- 200 – Primary circuit: intact loop
- 300 – Pressure vessel and upper head
- 400 – Steam generator: part of the secondary circuit of the broken loop
- 500 – Steam generator: part of the secondary circuit of the intact loop
- 600 – Pressurizer and its piping
- 700 – Accumulator of the intact loop and its piping
- 800 – Accumulator of the broken loop and its piping





- Module number
- Module location
- Module description
- Geometrical description
- Lengths
- Areas
- Volumes
- Pressure losses
- Connection to other modules


| Pressure vessel | | | | |
|------------------------------|--|---------------------------|-------------------------|----------|
| Parameters | Evaluation | Value | Remarks | |
| Module number | | 307 | | |
| Description | | Upper plenum part 2 | Vertical parallelepiped | |
| Outer rod bundle diameter | $D_{\text{bundle}}=10.75 \text{ mm}$ | $1.075 \cdot 10^{-2}$ | m | Draw. 13 |
| Barrel inside diameter | $D_{\text{barrel}}=198 \text{ mm}$ | $1.98 \cdot 10^{-1}$ | m | |
| Barrel outside pipe diameter | $D_{\text{out}}=288 \text{ mm}$ | $2.88 \cdot 10^{-1}$ | m | Draw. 13 |
| Number of rod bundle | 64 | | | Draw. 13 |
| Length | $L=2015+328=2343 \text{ mm}$ | 2.343 | m | Draw. 13 |
| Elevation change | 2015 mm | 2.015 | m | |
| Flow area | $S=S1-S2$ $S1=\pi \cdot D_{\text{barrel}}^2/4=\pi \cdot 198^2/4=30790.7 \text{ mm}^2$ $S2=64 \cdot \pi \cdot D_{\text{bundle}}^2/4=64 \cdot \pi \cdot 10.75^2=5808.8 \text{ mm}^2$ $S=24981.9 \text{ mm}^2$ | $2.4982 \cdot 10^{-2}$ | m^2 | Draw. 13 |
| Inside surface area | Heat exchange with downcomer $S_{\text{cylinder}} = 2\pi \cdot R \cdot H$ $SA=\pi \cdot D_{\text{barrel}} \cdot L=\pi \cdot 198 \cdot 2343=1457428 \text{ mm}^2$ | 1.457428 | m^2 | Draw. 13 |
| Outside surface area | Outer surface of barrel (part of module 301) $S_{\text{cylinder}} = 2\pi \cdot R \cdot H$ $SA=\pi \cdot D_{\text{out}} \cdot L=\pi \cdot 288 \cdot 2343=2119896 \text{ mm}^2$ | 2.119896 | m^2 | |
| Volume | $24981.9 \cdot 2343=58532592 \text{ mm}^3$ | $5.8532592 \cdot 10^{-2}$ | m^3 | |
| Pressure loss coefficient | Expansion 307→308 $k_{\text{down}}=0.5$ $k_{\text{rev}}=1$ | | | Tab. 4.2 |

- Accurate description of the measurement system




- Identify measured parameters
- Identify measurement locations
- Classify measurement insert types



To be considered in the pressure losses evaluation




- Pressure losses evaluation in the “reference status”
 - Modules number
 - Geometrical configuration
 - Parameters values and adopted formulas
 - K-loss coefficient
 - References

| N° | Element of system | Parameters | G_i kg/s | t °C | $v_i \cdot 10^{-7}$ m ² /s | ρ kg/m ³ | w_i m/s | $Re \cdot 10^6$ | Evaluation | k_{loc} | Remarks |
|---------|---|---|---------------|-----------|--|-----------------------------|--------------|-----------------|--|-----------|---------------------------------------|
| 306-307 | Expansion (forward)  | $\frac{F_0}{F_2} = \frac{8115}{24982} = 0.325$ | 28 | 326 | 1.26 | 654 | 5.29 | 4.26 | $k_{loc} = \left(1 - \frac{F_0}{F_2}\right)^2$ | 0.452 | Ref. [2] Sec. 4-1 (p. 146, 158) |
| | Expansion (reverse)  | $\frac{F_0}{F_1} = \frac{8115}{24982} = 0.325$ | 28 | 326 | 1.26 | 654 | 5.29 | 4.26 | $k_{loc} = 0.5 \left(1 - \frac{F_0}{F_1}\right)^{\frac{3}{4}}$ | 0.371 | Ref. [2] Sec. 4-9 (p. 151, 165) |
| 307-308 | Outlet from upper plenum: constriction (forward)  | $\frac{B}{D_r} = 0$ $\frac{\delta_1}{D_r} = 0$ | 0.4 | 294 | 1.26 | 740 | 0.6 | 0.16 | | 0.5 | Ref. [2] Sec. 3-1 (p. 122) |
| | Outlet from upper plenum: constriction (reverse) | | 0.4 | 294 | 1.26 | 740 | 0.6 | 0.16 | | 1 | Ref. [2] Sec. 11-1 p. 510 |

- The RDS-Test is related with the specific test performed in the facility and consists of the following **standard** sections
 - Test objective
 - Facility Description
 - ✓ Test configuration
 - ✓ Difference between facility “reference status” and test configuration
 - Test description
 - ✓ Boundary condition
 - ✓ Initial condition
 - Thermal-hydraulic system behavior
 - ✓ Main events and major captured phenomena
 - ✓ Thermal-hydraulic parameter trends (more than 40 time trends)

PD Vs length




Sequence of Events


| Events | Time (s) |
|--|----------|
| Break valve starts to open, blowdown initiated | 0 |
| Primary system pressure equal 132 bar (core heating power and secondary system isolation and cooldown) trip signals enabled) | 1.8 |
| Feedwater valves and steam valve at condenser inlet start to close Cooldown of secondary system initiated | 2.0 |
| Saturation in hot legs | 2.5 |
| Break valve fully open Core heating power decay starts | 3.0 |
| Feedwater valves and steam valve condenser inlet fully closed | 3.5 |
| Primary system pressure equal 117 bar (HPIS trip signal enabled) | 5.4 |
| Primary system pressure equal 110 bar (MCPs trip signal enabled) | 6.7 |
| Main coolant pumps coastdown initiated | 8.0 |
| Saturation in cold legs | 15.8 |
| PRZ surge line uncovers | 21.0 |
| Saturation in lower plenum | 31.0 |
| HPIS water injection initiated | 41.0 |

Relevant ICs

| Parameters | Location | Value |
|--------------------------|---|--|
| Primary System: | | |
| Mass Flow | Intact loop Broken loop | 20.8 kg/s 6.7 kg/s |
| Pressure | Upper plenum | 15.8 MPa |
| Fluid Temperature | Vessel outlet • Intact loop • Broken loop Vessel inlet • Intact loop • Broken loop | 327.9 °C 327.8 °C 296.2 °C 295.4 °C |
| Water Level | Pressurizer | c. 5.2 m |
| Temperature | Pressurizer | 346 °C |
| Power | Core | 5.20 MW |
| Water Volume | Accumulator • Intact loop • Broken loop | 246 l 76 l |
| Gas Volume | Accumulator • Intact loop • Broken loop | 34 l 18 l |
| Temperature | Accumulator • Intact loop • Broken loop | c. 30 °C c. 30 °C |
| Mass Flow | MCP seal water injection Intact loop Broken loop | 0.01 kg/s 0.0087 kg/s |
| Temperature | MCP seal water injection | c. 30 °C |
| Water Temperature | HPIS | 28 °C |
| Secondary System: | | |
| Mass Flow | Steam generator Intact loop Broken loop | 2.0 kg/s 0.66 kg/s |
| Pressure | Steam dome Intact Loop Broken Loop | 6.62 MPa 6.62 MPa |






Feedwater volumetric flow (short time)





Core power (short time)

Accumulators volumetric flows



- **Nodalization preparation**: main choices of the model characteristics and preliminary code resources distribution (**data from RDS**)
- **Nodalization schematization** according to the **pre-set nodalization strategies**
- **Writing input** following a **pre-set structure**
 - Specific care on avoiding typing error
- The **Qualification Report (QR)** collects the results of the qualification procedures of the code input and it is reviewed by the higher level analyst in the group






Geometrical Fidelity

| | QUANTITY | ACCEPTABLE ERROR (°) |
|----|---|----------------------|
| 1 | Primary circuit volume | 1 % |
| 2 | Secondary circuit volume | 2 % |
| 3 | Non-active structures heat transfer area (overall) | 10 % |
| 4 | Active structures heat transfer area (overall) | 0.1 % |
| 5 | Non-active structures heat transfer volume (overall) | 14 % |
| 6 | Active structures heat transfer volume (overall) | 0.2 % |
| 7 | Volume vs. height curve (i.e. “local” primary and secondary circuit volume) | 10 % |
| 8 | Component relative elevation | 0.01 m |
| 9 | Axial and radial power distribution (°°) | 1 % |
| 10 | Flow area of components like valves, pumps orifices | 1 % |
| 11 | Generic flow area | 10 % |

**Acceptable errors
-Geometrical Values-**



**Example of
“Volumes vs Elevation” curve**

Steady State Achievement


| | QUANTITY | ACCEPTABLE ERROR (%) |
|----|--|----------------------|
| 12 | Primary circuit power balance | 2 % |
| 13 | Secondary circuit power balance | 2 % |
| 14 | Absolute pressure (PRZ, SG, ACC) | 0.1 % |
| 15 | Fluid temperature | 0.5 % (**) |
| 16 | Rod surface temperature | 10 K |
| 17 | Pump velocity | 1 % |
| 18 | Heat losses | 10 % |
| 19 | Local pressure drops | 10 % (^) |
| 20 | Mass inventory in primary circuit | 2 % (^) |
| 21 | Mass inventory in secondary circuit | 5 % (^) |
| 22 | Flow rates (primary and secondary circuit) | 2 % |
| 23 | Bypass mass flow rates | 10 % |
| 24 | Pressurizer level (collapsed) | 0.05 m |
| 25 | Secondary side or downcomer level | 0.1 m (^) |

(*) The % error is defined as the ratio


$$\frac{|\text{reference or measured value} - \text{calculated value}|}{|\text{reference or measured value}|}$$

The “dimensional error” is the numerator of the above expression

Acceptable errors – TH quantities



Example of “pressure drop vs length” curve



Inherent drift criterion check


Qualitative Evaluation

- Use of CSNI phenomena
 - To evaluate the facility design, the experimental quality and the calculation performance
- Visual observation
 - Comparison between experimental and calculated time trends.
- Resulting time sequence of events
 - Calculated significant events and the timing of the events are compared with the experimental events
- Phenomenological Windows (Ph.W.)
 - PH.Ws should be distinguished
- Relevant Thermal-hydraulic Aspects (RTAs)
 - Inside each Ph.W., RTAs must be identified and characterized by numerical values of significant parameters


Quantitative Evaluation

$$AA = \frac{\sum_{n=0}^{2^m} |\tilde{\Delta}F(f_n)|}{\sum_{n=0}^{2^m} |\tilde{F}_{exp}(f_n)|}$$

$$WF = \frac{\sum_{n=0}^{2^m} |\tilde{\Delta}F(f_n)| \cdot f_n}{\sum_{n=0}^{2^m} |\tilde{F}_{exp}(f_n)|}$$



Geometrical fidelity and Steady-State achievement



“Volume vs Elevation” curve

| | N° | QUANTITY | UNIT | ACCEPT ERROR | EXP DATA | | CALC DATA | ERR. |
|------------------------------|----|--|------|--------------|----------------|---------|-----------|-------|
| | | | | | Y _r | ERROR | | |
| (A) Nodalization Development | 1 | Primary circuit volume | m³ | 1% | 7.81 | 0.00 | 7.750 | 0.77% |
| | 2 | Secondary circuit volume | | 2% | 6.65 | 0.00 | 6.624 | 0.39% |
| | 3 | Non Active structures heat transfer area (overall) | m² | 10% | NA | NA | --- | --- |
| | 4 | Core heat structure transfer surface area | | 0.10% | 73.259 | 0.02 | 73.250 | 0.00% |
| | 5 | SG U-tubes heat structure external surface area (without tube sheet) | 335 | | 2.00 | 336.944 | 0.00% | |
| | 6 | Maximum of the axial power distribution for the average rod in average channel (zone2) | KW/m | 1.0% | 26.95 | 2.05 | 25.165 | 0.00% |
| | 7 | Maximum of the axial power distribution for the hot rod in hot channel (zone4) | | 2.0% | 40.10 | 3.05 | 40.689 | 0.00% |


Geometrical fidelity check

| POSITION ALONG THE LOOP | | R5 COMP. | R5 [MPa] | EXP [MPa] |
|---|-----------|--------------|----------|-----------|
| Hot leg inlet | HL IN | 100010000 | 14.928 | 14.940 |
| Hot leg outlet | HL OUT | 107030000 | 14.922 | 14.937 |
| Steam generator inlet plenum | SG IN | 110010000 | 14.922 | Na |
| U-tube top | UT TOP | 112070000 | 14.901 | Na |
| Steam generator outlet plenum | SG OUT | 114010000 | 14.913 | Na |
| Bottom of loop seal | LOOP SEAL | 116050000 | 14.920 | 14.899 |
| Pump inlet | PUMP IN | 118(9)020000 | 14.917 | NA |
| Pump outlet | PUMP OUT | 124(5)020000 | 14.988 | NA |
| Cold leg in | CL IN | 126010000 | 14.973 | 14.972 |
| Cold leg out | CL OUT | 136010000 | 14.967 | 14.966 |
| Lower plenum (0.15m from vessel bottom) | LP | 220010000 | 15.002 | NA |
| Core inlet | CORE IN | 232010000 | 14.980 | NA |
| Core outlet | CORE OUT | 245010000 | 14.967 | NA |


Pressure drops distribution

Geometrical fidelity and Steady-State achievement

Inherent drift criterion check



PS pressure




Core Outlet temperature

SS values achievement check


| N° | QUANTITY | UNIT | ACCEPT ERROR | EXP DATA | | CALC DATA | ERR. |
|----|--|--------|--------------|----------------|-------|-----------|--------|
| | | | | Y _r | ERROR | | |
| 1 | Primary circuit power balance | MW | 2.0% | 36.00 | 1.20 | 36.00 | 0.00% |
| 2 | Secondary circuit power balance | | | NA | NA | --- | --- |
| 3 | Primary system hot leg pressure | MPa | 0.10% | 14.94 | 0.10 | 14.928 | 0.00% |
| 4 | PRZ pressure | | | 14.95 | 0.10 | 14.911 | 0.00% |
| 5 | SG exit pressure | | | 5.85 | 0.06 | 5.838 | 0.00% |
| 6 | Accumulator A pressure | | | 4.29 | 0.06 | 4.290 | 0.00% |
| 7 | Intact loop HL temperature (near vessel) | | | K | 0.50% | 589.50 | 4.20 |
| 8 | Intact loop CL temperature (near vessel) | 556.40 | 4.30 | | | 557.10 | 0.00% |
| 9 | Reactor vessel downcomer temperature | 555.00 | 4.00 | | | 557.50 | 0.00% |
| 10 | Broken loop HL temperature (near vessel) | 561.90 | 4.30 | | | 561.50 | 0.00% |
| 11 | Broken loop CL temperature (near vessel) | 554.30 | 4.20 | | | 557.00 | 0.00% |
| 12 | Intact loop pressurizer temperature | 615.60 | 0.70 | | | 614.90 | 0.00% |
| 13 | Pump velocity | rpm | 1.0% | 1250.00 | 70.00 | 1262.70 | 0.00% |
| 14 | Heat losses | - | NA | NA | NA | --- | --- |
| 15 | RPV pressure loss | | 10.0% | 26.00 | 1.90 | 28.00 | 0.36% |
| 16 | Core pressure loss | | | NA | NA | --- | --- |
| 17 | PS total loop pressure loss | | | 75.00 | 20.30 | 52.00 | 4.94% |
| 18 | Total mass inventory in PS | Kg | 2.0% | NA | NA | 5900.0 | - |
| 20 | Total mass inventory in SG | | 5.0% | NA | NA | --- | --- |
| 21 | PS total loop coolant mass flow | Kg/s | 2.0% | 192.40 | 7.80 | 191.90 | 0.00% |
| 22 | SG feedwater mass flow | | | 19.10 | 0.40 | 19.51 | 0.05% |
| 23 | Core coolant mass flow rate | | | NA | NA | --- | --- |
| 24 | Core bypass mass flow (LP-UP) | | | 10% | NA | 19.5 | --- |
| 25 | Pressurizer level (collapsed level) | | 0.05 | 1.14 | 0.03 | 1.14 | 0.0000 |
| 26 | Secondary side or downcomer level | | 0.1 | NA | NA | --- | --- |

(B) Nodalization qualification at Steady State


Qualitative Evaluation



Intact HL pressure



Break mass flow rate



PCT

| EVENT | Time (s) | | |
|---|----------------------|-------|-------|
| | EXP | ERR | CALC |
| Experiment L2-5 initiated | 0.0 | - | 0.0 |
| Subcooled blowdown ended | 0.043 | ±0.01 | 0.032 |
| Reactor scrammed | 0.24 | ±0.01 | 0.24 |
| Cladding temperature initially deviated from saturation | 0.91 | ±0.2 | 0.3 |
| Primary coolant pumps tripped | 0.94 | ±0.01 | 0.94 |
| Subcooled break flow ended (cold leg) | 3.4 | ±0.5 | 0.1 |
| Partial rewet initiated | 12.1 | ±1.0 | 8.2 |
| Pressurizer emptied | 15.4 | ±1.0 | 15.3 |
| Accumulator A injection initiated | 16.8 | ±0.1 | 15.1 |
| Partial rewet ended | 22.7 | ±1.0 | 15.1 |
| HPIS injection initiated | 23.9 | ±0.02 | 23.9 |
| Maximum cladding temperature reached | 28.47 | ±0.02 | 5.2 |
| LPIS injection initiated | 37.32 | ±0.02 | 37.32 |
| Accumulator emptied | 49.6 | ±0.1 | 52.0 |
| Core cladding quenched | 65.0 | ±2 | 65.5 |
| BST maximum pressure reached | 72.5 | ±1.0 | - |
| LPIS injection terminated | 107.1 ^{III} | ±0.4 | - |

Time sequence of events

Qualitative Evaluation

| RTA | RTA Parameter | UNIT | EXP | R5 | Judg. R5 |
|----------------------------------|---|------|-------|-------|------------------|
| RTA: Critical Flow | | | | | |
| TSE | Time of maximum break mass flow rate | s | 0.1 | 0.1 | E |
| | Time of two-phase flow at the break | s | 0.043 | 0.032 | R |
| SVP | Maximum break mass flow rate | kg/s | 869 | 1073 | R |
| IPA | Integral break mass flow at: | | | | |
| | - two-phase flow at the break occurrence | kg | 243 | 53 | R |
| | - dryout occurrence | kg | 595 | 435 | R |
| | - PRZ emptying time | kg | 3638 | 4719 | R |
| | - ACC injection time | kg | 3790 | 4693 | R |
| | - minimum PS mass inventory occurrence | kg | 4003 | 5332 | R |
| | - HPIS injection time | kg | 4114 | 5332 | R |
| | - PCT time | kg | 4238 | 2658 | M |
| | - LPIS injection time | kg | 4408 | 5684 | R |
| | - core quenching occurrence | kg | 4804 | 5927 | R |
| - end of calculation (t=100 s.) | kg | 5280 | 6134 | R | |
| RTA: Pressurizer behavior | | | | | |
| TSE | Time of emptying | s | 15.4 | 15.3 | E |
| | Time of PRZ pressure equal to PS pressure | s | 38.0 | 40.0 | E |
| SVP | PRZ pressure at: | | | | |
| | - two-phase flow at the break occurrence | MPa | 14.77 | 14.87 | E |
| | - dryout occurrence | MPa | 14.55 | 14.4 | E |
| | - PRZ emptying time | MPa | 8.85 | 7.78 | R |
| | - ACC injection time | MPa | 7.17 | 7.96 | R |
| | - HPIS injection time | MPa | 2.88 | 2.79 | E |
| | - PCT time | MPa | 1.62 | 12.8 | M |
| | - LPIS injection time | MPa | 0.73 | 0.56 | R |
| | - core quenching occurrence | MPa | 0.67 | 0.48 | R |
| | RTA: Primary System behaviour | | | | |
| TSE | Time of UP in saturation condition | s | 0.18 | 0.2 | E |
| | Time of PS pressure equal to SS pressure | s | 10.1 | 9.9 | E |
| SVP | PS pressure at: | | | | |
| | - two-phase flow at the break occurrence | MPa | 10.15 | 10.2 | E |
| | - dryout occurrence | MPa | 9.69 | 10.6 | M ^{2/3} |
| | - PS equal to SS pressure occurrence | MPa | 5.71 | 5.73 | E |
| | - PRZ emptying time | MPa | 4.73 | 4.24 | R |
| | - ACC injection time | MPa | 4.25 | 4.3 | E |
| | - minimum PS mass inventory occurrence | MPa | 2.56 | 1.77 | R |
| | - HPIS injection time | MPa | 1.76 | 1.77 | E |
| | - PCT time | MPa | 0.91 | 7.2 | M |
| | - LPIS injection time | MPa | 0.5 | 0.45 | E |
| - core quenching occurrence | MPa | 0.47 | 0.47 | E | |
| RTA: Core power behaviour | | | | | |
| TSE | Time of dryout | s | 0.91 | 0.6 | R |
| | Time of peak cladding temperature (PCT) | s | 28.47 | 5.2 | R |
| | Time of core quenching | s | 65.1 | 65.5 | E |
| SVP | Peak cladding temperature | °C | 1078 | 1114 | E |

| RTA | RTA Parameter | UNIT | EXP | R5 | Judg. R5 |
|---|---|------|--------|--------|----------|
| RTA: Accumulator Behaviour | | | | | |
| TSE | ACC injection time | s | 16.8 | 15.1 | R |
| | Time of ACC emptied | s | 49.6 | 52.0 | E |
| SVP | ACC pressure at core quenching occurrence | MPa | 0.98 | 0.63 | R |
| IPA | Integral ACC mass flow at: | | | | |
| | - minimum PS mass inventory occurrence | kg | 123.9 | 312.0 | R |
| | - PCT time | kg | 516.6 | 0.0 | M |
| | - core quenching occurrence | kg | 1504 | 1570 | E |
| | - end of calculation (t=100 s.) | kg | 1506 | 1584 | E |
| RTA: HPIS Behaviour | | | | | |
| TSE | HPIS injection time | s | 23.9 | 23.7 | - |
| SVP | HPIS mass flow rate at: | | | | |
| | - core quenching occurrence | kg/s | 0.74 | 0.79 | E |
| | - end of calculation (t=100 s.) | kg/s | 0.75 | 0.79 | E |
| IPA | Integral HPIS mass flow at: | | | | |
| | - core quenching occurrence | kg | 33.3 | 30.24 | E |
| | - end of calculation (t=100 s.) | kg | 59.5 | 60.36 | E |
| RTA: LPIS Behaviour | | | | | |
| TSE | LPIS injection time | s | 37.32 | 37.1 | - |
| SVP | LPIS mass flow rate at: | | | | |
| | - core quenching occurrence | kg/s | 5.67 | 5.71 | E |
| | - end of calculation (t=100 s.) | kg/s | 7.21 | 6.1 | R |
| IPA | Integral HPIS mass flow at: | | | | |
| | - core quenching occurrence | kg | 146.8 | 173.0 | R |
| | - end of calculation (t=100 s.) | kg | 376.66 | 310.0 | R |
| RTA: Secondary System behavior | | | | | |
| SVP | SS pressure at: | | | | |
| | - two-phase flow at the break occurrence | MPa | 5.84 | 5.84 | E |
| | - dryout occurrence | MPa | 5.84 | 5.85 | E |
| | - ACC injection time | MPa | 5.68 | 5.69 | E |
| | - HPIS injection time | MPa | 5.68 | 5.67 | E |
| | - PCT time | MPa | 5.69 | 5.81 | R |
| | - LPIS injection time | MPa | 5.64 | 5.65 | E |
| - core quenching occurrence | MPa | 5.59 | 5.60 | E | |
| RTA: Mass Distribution in Primary System (*) | | | | | |
| TSE | Time of minimum PS mass inventory | s | 21 | 23.7 | E |
| SVP | Minimum PS mass inventory | kg | 2020.8 | 928.6 | R |
| | PS mass inventory at: | | | | |
| | - two-phase flow at the break occurrence | kg | 5656.3 | 5926.4 | R |
| | - dryout occurrence | kg | 5326.5 | 5522.5 | R |
| | - ACC injection time | kg | 2143.3 | 1258.6 | R |
| | - HPIS injection time | kg | 2056.1 | 928.6 | R |
| | - PCT time | kg | 2183.2 | 3294.4 | M |
| | - LPIS injection time | kg | 2480.7 | 1200.0 | R |
| | - core quenching occurrence | kg | 2780.4 | 1784.6 | R |


Quantitative Evaluation

| | PARAMETER | AA | WF |
|--------------|---|--------------|--------------|
| 1 | Intact loop hot leg pressure | 0.076 | 0.203 |
| 2 | Pressurizer pressure | 0.051 | 0.108 |
| 3 | Accumulator pressure | 0.103 | 0.093 |
| 4 | Secondary side steam dome pressure | 0.013 | 0.379 |
| 5 | Fluid temperature at fuel bundle bottom | 0.039 | 0.269 |
| 6 | Fluid temperature at fluid bundle top | 0.135 | 0.207 |
| 7 | Fluid temperature at core inlet | 0.063 | 0.271 |
| 8 | Fluid temperature at core outlet | 0.082 | 0.288 |
| 9 | Fluid temperature at BL CL nozzle | 0.069 | 0.275 |
| 10 | Fluid temperature at HL IL nozzle | 0.239 | 0.180 |
| 11 | Fluid temperature at SG IL in | 0.122 | 0.192 |
| 12 | Fluid temperature at SG IL out | 0.109 | 0.244 |
| 13 | Fluid Temperature at BL HL nozzle | 0.256 | 0.179 |
| 14 | Pressurizer level | 0.040 | 0.214 |
| 15 | Accumulator level | 0.599 | 0.083 |
| 16 | Cladding temperature, zone 1, bottom level | 0.234 | 0.306 |
| 17 | Cladding temperature, zone 4, 2/3 level (PCT) | 0.315 | 0.223 |
| 18 | Cladding temperature, zone 1, 2/3 level | 0.635 | 0.217 |
| 19 | Cladding temperature, zone 2, top level | 0.228 | 0.270 |
| 20 | Cladding temperature, zone 4, top level | 0.297 | 0.205 |
| 21 | Mass flow at cold leg break | 0.443 | 0.274 |
| 22 | Mass flow at hot leg break | 0.702 | 0.232 |
| TOTAL | | 0.178 | 0.255 |

- EH contains the **technical rationale** for the input provides the **engineering justifications** of the adopted assumptions and allows the **verification** of the model's input file
 - Methods and assumptions used to convert the RDS-Facility and RDS-Test information into the code input data
 - Nodalization schemes of the components
 - The calculation notes (traceability of the information)
 - Adequate description and explanation of adopted modeling assumptions

- By the EH, information and knowledge of the input files can be transferred easier in time and to different groups

- Final step of the process to set up a **qualified database**, IAEA states that a: “documents contains a full description of how the database has been converted into an input data deck for a specific computer code”, (IAEA, SRS n°23) should be available



- Relap5-3D © nodalization description

| General Zone | Zone | Name | Number | Type | Document Section | |
|---------------------|--------------|----------|----------|--------|------------------|---------|
| Primary Side | | | | | | |
| Intact Loop | IL HL | ILHL-1 | 100 | BRANCH | 2.2.3.1 | |
| | | ILHL-2 | 105 | BRANCH | | |
| | | ILHL-3 | 110 | PIPE | | |
| | IL SG | ILSG-IN | 115 | BRANCH | 2.2.3.2 | |
| | | IL-UT | 120 | PIPE | | |
| | | ILSG-OUT | 125 | BRANCH | | |
| | IL LOOP SEAL | ILLS-1 | 130 | PIPE | 2.2.3.3 | |
| | IL PUMP | IL-PUMP | 140 | PUMP | 2.2.3.4 | |
| | IL CL | IL CL | ILCL-1 | 150 | PIPE | 2.2.3.5 |
| | | | ILCL-2 | 160 | BRANCH | |
| ILCL-3 | | | 170 | BRANCH | | |
| Broken Loop | BL HL | BLHL-1 | 200 | BRANCH | 2.2.5.1 | |
| | | BLHL-2 | 205 | BRANCH | | |
| | | BLHL-3 | 210 | PIPE | | |
| | BL SG | BL SG | BLSG-IN | 215 | BRANCH | 2.2.5.2 |
| | | | BL-UT | 220 | PIPE | |
| | | | BLSG-OUT | 225 | BRANCH | |
| | BL LOOP SEAL | BLLS-1 | 230 | PIPE | 2.2.5.3 | |
| | BL PUMP | BL-PUMP | 240 | PUMP | 2.2.5.4 | |
| | BL CL | BL CL | BLCL-1 | 250 | SINGVOL | 2.2.5.5 |
| | | | BL-ROTOR | 251 | VALVE | |
| | | | BLCL-2 | 255 | PIPE | |
| | | | BLCL2 | --- | --- | |
| | | | BLCL-3 | --- | --- | |

TH components


Link to the document section (component by component)

User friendly

Control system components

| General Location | Location | Control Variable Number | Control variable Name | Experimental Channel Measurement Correspondence | Description | Reference | |
|------------------|---------------------------|---------------------------|-----------------------|---|---------------------|-----------|---------------|
| IL LEVEL | Pressurizer | 4209 | PRZ L1 | - | | 5.1.1.1 | |
| | | 4309 | PRZ L | - | | | |
| | IL U-tubes ascending side | IL U-tubes ascending side | 1159 | ILSGIN-L | CL90AB+1.19m-0.055m | | 5.1.1.1 |
| | | | 1189 | ILUTAS-L | CL90BP+2.995m | | |
| | | | 1199 | ILUTAS-L | - | | |
| | | | 1219 | ILUTDS-L | - | | |
| | | | 1229 | ILUTDS-L | CL92BP+2.955m | | |
| | | | 1259 | ILSGOT-L | CL93AB+1.19m-0.055m | | |
| | | | 1299 | ILLS-1 | - | | |
| | | | 1309 | ILLS-2 | - | | |
| 1319 | ILLS-L | CL1792X3 | | | | | |
| BL LEVEL | BL U-tubes ascending side | 2159 | BLSGIN-L | CL80+1.045m -0.02m | | 5.1.1.2 | |
| | | 2189 | BLUTAS-L | CL80BP+2.95m | | | |
| | | 2199 | BLUTAS-L | CL80BP+2.95m | | | |
| | | 2219 | BLUTDS-L | - | | | |
| | | 2229 | BLUTDS-L | CL82BP+2.95m | | | |
| | | 2259 | BLSGOT-L | CL82AB+0.045m-0.02m | | | |
| | | 2309 | BLLS-1 | - | | | |
| 2319 | BLLS-L | CL2782x2 | | | | | |
| RPV LEVEL | RPV Core Level | 3295 | RPVCOR-1 | - | | 5.1.1.3 | |
| | | 3309 | RPVCOR-L | - | | | |
| | RPV Riser Level | 3159 | RPVRSR-1 | - | | | |
| | | 3409 | RPVRSR-3 | - | | | |
| | RPV Downcomer Level | RPV Downcomer Level | 3459 | RPVRSR-L | CL3RYA | | Approximately |
| | | | 3009 | RPVDC-1 | - | | |
| | | | 3019 | RPVDC-2 | - | | |
| | | | 3029 | RPVDC-3 | - | | |
| 3059 | RPVDC-L | CL3DYB+0.17m | | | | | |
| IL SG | IL SG Downcomer level | 6009 | ILSGDC-1 | - | | 5.1.1.4 | |
| | | 6359 | ILSGDC-L | - | | | |

- Cross link between (RDS) Drawings and Nodalization



- Conversion from RDS data (code-independent) to input data (code-dependent)

5 LOGIC AND CONTROL SYSTEM

5.1 Control Variables

5.1.1 Level

Table 5-1 summarized the level control variable that are present in the RELAP5 input. In the present Table 5-1, the control variable related to a particular part of the ITF are grouped together (the same approach has been used in the input file). For each control variable the location of the level measurement is identified (second column), the correspondence with the ITF measurement channel is given in the fifth column. For each control variable the last column of Table 5-1 provide the reference to the section that the described the specific control variable.

5.1.1.1 Pressurizer level

The pressurizer level is calculated summing the liquid void fraction in each cells multiplied by the elevation change of each cell for which the variable "voidf" is calculated (Equation 2-1 and Equation 2-2). Two control variable are used to calculated the actual collapsed level of the pressurizer: 4209 and 4309.

Control variable 4209:

$$\begin{aligned} PRZ_L1 = & 0.395 \cdot voidf\ 420_01 + 0.395 \cdot voidf\ 425_01 + 0.585 \cdot voidf\ 430_01 + \\ & + 0.5 \cdot voidf\ 430_02 + 0.5 \cdot voidf\ 430_03 + 0.5 \cdot voidf\ 430_04 + \\ & + 0.5 \cdot voidf\ 430_05 + 0.345 \cdot voidf\ 430_06 \end{aligned} \quad \text{Equation 5-1}$$

Control variable 4309:

$$\begin{aligned} PRZ_L = & 0.336 \cdot voidf\ 430_07 + 0.5 \cdot voidf\ 430_08 + 0.5 \cdot voidf\ 430_09 + \\ & + 0.6 \cdot voidf\ 430_10 + 0.6 \cdot voidf\ 430_11 + 0.705 \cdot voidf\ 430_12 + \\ & + 0.705 voidf\ 440_01 + 1.0 \cdot cntrlvar\ 4209 \end{aligned} \quad \text{Equation 5-2}$$

5.1.1.1 Intact Loop Level

Intact Loop Steam Generator Inlet Global Level (CNTRLVAR 1159)

Control variable 1159 calculates the collapsed liquid level in the inlet pipe of the intact loop steam generator, it corresponds to measurement channel "CL90AB" +1.19 m – 0.055 m. The collapsed liquid level is calculated summing the liquid void fraction in each cells multiplied by the elevation change of each cell for which the variable "voidf" is calculated (Equation 5-3). The initial value for the variable is 2.9 m.

Control variable 1159:

$$\begin{aligned} ILSGIN_L = & 0.83 + 0.458 \cdot voidf\ 110_08 + 0.4 \cdot voidf\ 110_09 + \\ & + 0.4 \cdot voidf\ 110_10 + 0.3 \cdot voidf\ 110_11 + \\ & + 0.2 \cdot voidf\ 110_12 + 0.312 \cdot voidf\ 115_01 \end{aligned} \quad \text{Equation 5-3}$$

2.2.1.2 Lower Plenum

HYDRO COMPONENTS

- Rationale
- User choices
- Models (flag)
 - BRANCH 310 (HEMISPHERICAL HEAD)
- Default
- PIPE 315 (CORE INLET)
- Default
- Geometry Data
 - BRANCH 310 (HEMISPHERICAL HEAD)

Component 310 models the bottom of the reactor pressure vessel, it consists of the cylindrical part and the hemispherical bottom. The internal diameter of the core vessel is 0.312 m, the internal radius of the hemispherical bottom is 0.373 m and the average flow area of the component is $7.0954 \cdot 10^{-2} \text{ m}^2$ (Equation 2-7). See Table 2-2 for detailed geometry summary.

$$A_{310} = V_{M302} / L_{M302} = 0.026465 / 0.373 = 7.0954 \cdot 10^{-2} \text{ m}^2 \quad \text{Equation 2-4}$$

- PIPE 315 (CORE INLET)

Component 315 models the entrance region to the core barrel. It is subdivided in 3 cells, the total length is 1.006 m and the average flow area is $2.5651 \cdot 10^{-2} \text{ m}^2$ (Equation 2-5). The component PIPE 315 corresponds to module 303. See Table 2-2 for detailed geometry summary.

$$A_{315} = V_{M303} / L_{M303} = 0.025805 / 1.006 = 2.5651 \cdot 10^{-2} \text{ m}^2 \quad \text{Equation 2-5}$$

- Computational tools in BEPU analyses includes:
 - BE Computer codes
 - Nodalization
 - ✓ Procedure for development and qualification
 - ✓ Procedure to address the “code-user-effect”
 - Uncertainty methodology
 - ✓ Procedure for the validation of the methodology
 - ✓ Procedure to address the “uncertainty-method-user-effect”
 - Platform for coupling and interfacing different codes


- The SCCRED is applicable in the V&V of all the BEPU computational tools

Relevant experimental data  **Qualified computational tool**


- A key feature of BEPU methodologies is to adopt a **validated UM**
 - Improvements and validation of the present UM are necessary
 - ✓ UMS, BEMUSE → PREMIUM project focused on the “uncertainty-method-user-effect”



- Spread of uncertainty Bands for cladding temperature
 - Similar uncertainty methods (propagation of input uncertainty parameters) and in some cases the same thermal-hydraulic code




UMS (1995)



BEMUSE (2009)



- The Propagation of Code Input Errors

- Need to Implement V&V Concepts to characterize:
 - ✓ Input Uncertainty Parameters
 - ✓ Ranges of variation of Input Uncertainty parameters
 - ✓ Probability Distribution Functions



- The Propagation of Code Output Errors


- V&V concepts are (inherently) part of the approach



- Predictive Modeling Methodology


- V&V concepts are (inherently) part of the approach

Relevant experimental data ↔ Qualified computational tool



- SCCRED methodology: needed to the V&V process of UM based on the “propagation of output errors”

- CIAU and CIAU-TN bases:
 - Use of systematic **qualification** process
 - The ‘NPP status approach’ to identify ‘phase spaces’ to which associate single uncertainty values for each of the selected – output – quantities
 - The ‘separation and recombination of time and quantity ‘error’
 - ‘error filling process’ and ‘error extraction process’
 - ✓ accuracy database → uncertainty database for the uncertainty evaluation of the **qualified** NPP code calculation.



- Should be a mandatory requirement also for
 - predictive modeling methodology
 - “propagation of input uncertainties” methods to validate the selection of
 - ✓ Input uncertainty parameters
 - ✓ Associated ranges of variations and the PDFs

} **Reduce the uncertainty-method-user effect**

- Main outcomes deriving from the application of the SCCRED methodology:
 - Demonstration of the code qualification level
 - Reduction of code-user-effect
 - ✓ Code user guidelines
 - ✓ User discipline & QA procedure in development of the nodalization, analysis of the results and documentation
 - Traceability of user choice and derivation of input data
 - Database of experimental data and associated code calculations
 - derivation and availability of an accuracy database
 - Demonstration of the qualification level of the accuracy database;
 - Reduction of the uncertainty-method-user effect
 - Application of the desired level of quality assurance when a BEPU approach is applied in licensing framework
 - Possibility to perform a V&V of BEPU applications(BE computational codes and associated uncertainty methodologies)