



UNIVERSITÀ DI PISA

UNIVERSITÀ DI PISA



N.I.N.E.

www.nineeng.com



Nuclear and Industrial Engineering

**The BEPU Evaluation Model with RELAP5-3D©
for the Licensing of Atucha-II NPP**

A. Petruzzi, M. Cherubini, M. Lanfredini (UNUPI-NINE)
F. D'auria (UNUPI), O. Mazzantini (NA-SA)



- Atucha-II NPP short description
- The BEPU approach for the Licensing of Atucha-II NPP
 - Boundary and Initial conditions
 - Selected Scenarios and computational tools
- RELAP5-3D© Nodalizations
 - 60 channels (coupled with the I&C code)
 - 280 channels (coupled with the 3D-NK code)
 - Containment
- Qualification of the RELAP5-3D© Evaluation Models
 - Approach adopted for the Scaled Analyses
 - Verification of the I&C modelling
- Selected example
 - Turbine Trip
 - Control Rod Ejection
 - 2A-LOCA in CL
- Conclusions

- Primary circuit characteristics (D2O cooled and moderated)
 - 2 U-Tubes SG, 2 MCP
 - Primary side pressure: 11.5 MPa
 - Primary side temperatures: 278 °C at RPV inlet, 313.3°C at RPV outlet
 - Thermal power: 2161 MW
- Moderator circuit (Normal operation and RHR\ECC)
 - Same pressure of the Primary circuit
 - AVG Moderator Temperature: 170-220 °C
 - 4 U-Tubes HX for Moderator cooling / FW pre-heating





- RPV characteristics

- 451 fuel channels vertically oriented
- 37 fuel rods per channel (UO2 nat)
- On-line refueling
- Active core length: 5,3m
- Oblique Control Cods



- Reactivity control system


- Moderator temperature
- Oblique Control Rods
- Emergency Boron Injection System (JDJ) → during RIA (e.g. LB-LOCA)



- Methodology for accident analysis in NPP licensing
 - Comply with the established Regulatory requirements
 - Adequate and complete spectrum of events
 - ✓ deterministic and probabilistic methods
 - Availability of qualified tools and procedure for accident analysis
 - ✓ Conservative, BEPU

- Atucha-II Accident analysis for FSAR → “The BEPU description document”
 1. Evaluation of the possibility to use a BEPU approach within the context of the current national Regulatory Authority requirements
 2. Review of the experiences acquired in the use of Best Estimate analyses for licensing
 3. Structure of the BEPU
 - a) Categorization of PIE
 - b) Grouping of events
 - c) identification of analysis purposes
 - d) identification of applicable acceptance criteria
 - e) ‘General scope’ Evaluation Model (EM) and of related requirements (from expected phenomena)
 - f) Selection of the qualified computational tools + BIC
 - g) Characterization of assumptions for the Design Basis Spectrum
 - h) Performing the analyses
 - i) Adopting a suitable uncertainty method

- Initial condition in Atucha-II safety analyses
 - “normal operation shall be assumed as the **initial plant condition** for the analysis of chain of events. In each case, the **most probable operating condition** of the plant shall be chosen in view of the effects of an event”
 - ✓ Take credit of the **acceptable** limitation system
- Boundary condition (for I&C) based on full BE calculation (Case A, Case B)




- Three categories of PIE (PSA supported)
 - AOO: $f > 10e-2/\text{year}$
 - DBA : $10e-5/\text{year} < f < 10e-2/\text{year}$
 - SBDBA : $f < 10e-5/\text{year}$
- 2A-LOCA is a SBDBA
- 83 scenarios subdivided in 9 families identified.
 - Three evaluation purposes for each scenario (RCA, CSA, CBA)

No	Transient	Section FSAR	Adopted Evaluation Model	Class of Accident
Increase in Heat Removal by the Secondary System		15.1		
1	Feed-Heater Train System Malfunctions that result in a Decrease in FW Temperature (Loss of low Pressure Feed Heater Trains)	15.1.1	CSA	AOO
2	FW System Malfunctions that result in an Increase in FW Flow (Stuck Open FW Control Valve)	15.1.2	CSA	AOO
3	Steam Pressure Regulator Malfunction or Failure that results in Increasing Steam Flow	15.1.3	CSA	AOO
4	Inadvertent Opening of a SG-RV or Safety Valve (Stuck Open Isolation of Safety Valve as a Single Failure)	15.1.4	CSA	DBA
Spectrum of Steam System Piping Failures inside and outside of Containment (MSLB)		15.1.5		
5	Leak of MS Line inside the Containment	15.1.5.1	CSA/RCA/CBA	DBA
6	2A MS Line Rupture Downstream Isolation Valve	15.1.5.2	CSA/CBA	DBA
7	2A MS Line Rupture Outside Containment	15.1.5.3	CSA/RCA	DBA
8	Inadvertent Connection of the DHRS to the FW System	15.1.6	QA	AOO
9	Inadvertent Closing of the Moderator Cooler Bypass CV	15.1.7	CSA	AOO
Decrease in Heat Removal by the Secondary System (part 1 of 2)		15.2		
10	Steam Pressure Regulator Malfunction or Failure that results in Decreasing Steam Flow	15.2.1	CSA	AOO
11	Loss of Electric Load	15.2.2	CSA	AOO
12	Turbine Trip (Closure of Stop Valve)	15.2.3	CSA	AOO
MSIV Malfunction		15.2.4		
13	Inadvertent Closing one MSIV	15.2.4.1	CSA	AOO
14	Inadvertent Closing all MSIV	15.2.4.2	CSA	DBA
15	Loss of Condenser Vacuum	15.2.5	CSA	AOO
Emergency Power Mode (EPM)		15.2.6		
16	Coincident Loss of Onsite and External (Offsite) AC Power to the Station (Short-term EPM)	15.2.6.1	CSA	AOO
17	Coincident Loss of Onsite and External (Offsite) AC Power to the Station (Long-term EPM)	15.2.6.2	RCA	DBA

No	Transient	Section FSAR	Adopted Evaluation Model	Class of Accident
Decrease in Reactor Coolant System Inventory (part 2 of 2)		15.6		
Spectrum of LOCA		15.6.5		-
Primary Coolant System LOCA		15.6.5.1		-
Small Break LOCA		15.6.5.1.1		-
50	30 cm2 LOCA cold	15.6.5.1.1.1	CSA	DBA
51	100 cm2 LOCA cold	15.6.5.1.1.2	CSA	DBA
52	Break of the Refueling Nipple	15.6.5.1.1.3	CSA	DBA
Intermediate Break LOCA		15.6.5.1.2		-
53	200 cm2 LOCA cold	15.6.5.1.2.1	CSA/CBA	DBA
54	LOCA in PRZ Surge-Line	15.6.5.1.2.2	CSA	DBA
55	0.1A LOCA cold	15.6.5.1.2.3	CSA/RCA/CBA	DBA
56	0.1A LOCA cold with Sump Swell Operation	15.6.5.1.2.4	QA	DBA
Large Break LOCA		15.6.5.1.3		-
57	2A LOCA cold (DEGB. Different Break Sizes and Positions are investigated)	15.6.5.1.3.1	CSA/RCA/CBA	SBDBA
58	2A LOCA hot	15.6.5.1.3.2	CSA/CBA	SBDBA
Moderator Loop LOCA		15.6.5.2		-
59	50 cm2 Small Leak in Moderator Suction Line	15.6.5.2.1	CSA	DBA
60	0.1A Leak in Moderator Injection Line	15.6.5.2.2	CSA	DBA
61	2A Break in the Moderator Line at Pump Suction (DEGB)	15.6.5.2.3	CSA	SBDBA
62	Break in the Largest Pipe connected with the Moderator Lines	15.6.5.2.4	CSA	DBA
63	Break in the Moderator Line at RPV Connection (DEGB)	15.6.5.2.5	CSA	SBDBA
64	CVCS Malfunction that decreases RCS mass Inventory	15.6.6	CSA	AOO
Radioactive Release from a Sub-system		15.7		
65	Radioactive Gas Waste System Leak or Failure	15.7.1	RCA	DBA
66	Radioactive Liquid Waste System Leak or Failure	15.7.2	RCA	DBA
67	Radioactive Release due to Liquid Tank Failure	15.7.3	RCA	DBA
68	Design Bases Fuel Handling Accidents	15.7.4	- (2)	DBA
69	Spent Fuel Cask Drop Accident	15.7.5	QA	DBA
70	Failure During Tritium Extraction Operation and Storage	15.7.6	RCA	DBA

- Qualified computational tools adopted in the BEPU FSAR of Atucha-II
 - More than ten computer codes with several interaction (TH-SYS code is the central process)
 - More than 20 nodalization developed
 - Suitable qualification process
 - Uncertainty evaluation (CIAU)

6 different R5-3D nodalization





#	CODE	NODALIZATION	OBJECTIVE	#	CODE	NODALIZATION	OBJECTIVE
1-1	RELAP5-3D© (only TH Model)	60-ch	D	13-3	ANSYS-CFX	Boron Lances	S
2-1		280-ch	D	14-4	ANSYS	RPV-w	D
3-1		451-ch	S	15-5	TRANSURANUS	Fpin	D
4-1		DNBR	D	16-6	NESTLE	451-10nk	D
5-1		CONT-R	D	20-8	MCNP	Core-M	S
6-2	DYNETZ	I&C-AT2	D	21-9	NEWT-ORIGEN	FCell-S	D
7-3	ANSYS-CFX	MOD-T	D	24-13	DRAGON	FCell-D	S
8-3		DC-LP	D (PTS)	25-13	MCNP-ORIGEN	FCell-M	D
9-3		UP	S	26-14	RELAP5-3D© (Rad Model)	60ch-3D	D
10-3		FC Inlet	S	27-15	MELCOR-MACCS	ENV-M	D
11-3		FC outlet	S	28-15		CONT-M	S
12-3		Grid Spacer	S	30-17		RODOS	ENV-R



- The RELAP5-3D© 60-Channels Nodalization

- Main nodalization adopted in the safety analyses of Atucha-II FSAR
- Fictitious 3D approach
- Two different coupling developed for I&C modelling (Dynetz)
 - ✓ Detailed description of the Secondary Side, Moderator System and auxiliary system (e.g. CVCS)


Code resources	Number
Volumes	2609
Junctions	3139
Heat Structures	2861
Mesh Points	22195
Trips	45
Control Variables	4316



- Sample of the Fictitious 3D developed with CFD support calculations
 - Adopted in the BEMUSE project (Zion NPP) and UPTF calculations





- Sample of the nodalization of the SS and ML systems



- The RELAP5-3D© 280-Channels Nodalization
 - 3D-NK NESTLE model
 - ✓ Special technique to take into account the Control Rod inclination (XS corrected with MCNP calc.)
 - MULTID components to model the Moderator Tank
 - 2 different techniques for CFD interfacing (boron injection)
- Inclined control rods (17°-25°) constituted by 2 different material (axially)
- “fictitious moderator tank” approach for boron feedback
 - Boron dilution (CFD) → boron concentration at 3D-NK resolution level


Code resources	Number	Code resources	Number
3D components	3	Geometry	hexagonal
Volumes	9770	Axial layer	12
Junctions	12864	Number of rings	14
Heat Structures	8157	Zones	4164
Mesh Points	52895	Regions (vol\HS)	2\1
Trips	45	Compositions	1670
Control Variables	40	Control rod groups	281




- The RELAP5-3D© Containment nodalization → pressure peak (e.g. 2A LOCA)
 - Careful investigation of the code capability
 - ✓ No Severe Accident, steam explosion, hydrogen combustion phenomena
 - ✓ Fission product distribution only in liquid phase
 - ✓ Limited data for mechanical loads on structures and components
 - Relevant phenomena can be investigated with **proper nodalization techniques**
 - ✓ Discharge of water and steam in the containment
 - ✓ Expansion of the steam in the containment rooms
 - ✓ Max pressure peak occurrence in short term
 - ✓ Heat exchange between the discharge water and containment environment and thermal structures
 - ✓ Condensation of the steam
 - ✓ Collection of the water from the break and condensing water
 - ✓ Injection of the collected water in the primary system
 - Specific care in modeling the obstacles (water on the floor and pool formation), rupture disks and fuse doors

Accident Group	Mass sources	Energy sources	Radioactivity sources	Mechanical and thermal loads on structures/components
Group I (PS break)	Relevant	Relevant	Relevant	Relevant
Group II (SS break or isolable PS break)	Not Relevant	Relevant	Negligible	Relevant
RELAP5-3D capability	Full	Full	Partial	Partial

- Sample of the nodalization scheme and adopted code resources




Code Resources	Number
Volumes	572
Junctions	1031
Heat Structures	558
Mesh Points	4120



- The SCCRED methodology was rigorously adopted (Qualification of the developed computational tools)
- The Features of Atucha-II NPP require a specific approach for the Kv scaling analyses for the assessment of the Evaluation Model

- **Demonstration of Code Phenomena Coverage**
- **Code validation**
 - ✓ Computer code
 - ✓ Nodalization Techniques
 - ✓ Accuracy evaluation
 - ✓ User qualification
- **Qualification of the Atucha-II nodalization**
 - ✓ Identification of the system/sub-system
 - ✓ Nodalization techniques @ system/sub-system level
 - ✓ “Kv+CT” analyses @ system/sub-system level
 - ✓ Verification of the I&C simulator (code-to-code)



- Nine different tests performed on five ITF selected for the “on transient” qualification of the Atucha-II nodalization (No prototypical ITF exists)
 - 9 qualified calculations (SCCRED)
 - Multiple similarity analyses at **full system** and **system/subsystem level**

- The presence of the moderator system requires proper Kv scaling approach
 - “Correction” of the power-to volume scaling factor (power and volume)
 - Sensitivity calculation considering the moderator tank


- The verification of the I&C simulator consider 10 NON-LOCA scenarios
 - Consider the actuation of the different I&C systems
 - Consider different plant status
 - Qualitative and quantitative analyses performed

● Scaling factors and selected test


No	Parameter	Reference CNA-II scaled model (w/o Moderator)	Sensitivity with Moderator
Steady-State Setup			
1	Power, W	$f \cdot W_{CNA2}^0$	$f \cdot W_{CNA2}$
2	Pump velocity, v	$f \cdot v_{CNA2}$	
3	PS pressure, P	P_{ITF}^0	
4	CL temperature, T_{CL}	T_{CL}^{ITF} adjust SS conditions (pressure, FW temp, FW flow) to achieve	
5	Linear heat rate, LHR	LHR_{CNA2} + sample with LHR_{ITF}^{max}	
6	PRZ volume, V_{PRZ}	$V_{PRZ}^{CNA2} \cdot \frac{V_{CNA2}^{PS}}{V_{CNA2}}$	V_{PRZ}^{CNA2}
Transient Setup			
7	Break area, A_{brk}	$A_{brk}^{ITF} \cdot K_T$	
8	Accumulator:		
	a) height	a) $H = H^{ITF}$	
	b) total volume	b) $V_{tot} = V_{tot}^{ITF} \cdot K_T$	
	c) liquid volume	c) $V_{liq} = V_{liq}^{ITF} \cdot K_T$	
	d) inj. line pressure loss	d) $K_{loss}^{ITF} / A_{ITF}^2$	
9	e) initial pressure	e) $P = P^{ITF}$	
	f) liquid temperature	f) $T = T^{ITF}$	
9	HPIS/LPIS:		
	a) supplied flow	a) $\dot{m} = \dot{m}^{ITF} \cdot K_T$	
	b) liquid temperature setpoint	b) $T = T^{ITF}$	
10	Power		
	a) scram setpoint b) decay curve	a) as in experiment b) experimental relative curve	
11	Secondary side pressure	As in experiment (imposed cooldown in LOCA)	
12	FW system		
	a) flow b) temperature	a) procedure as in experiment b) $T = T^{ITF}$	

#	Facility	Test	Type	CNA-II Phenomena	CNA-II System/Sub-System
1	LOBI MOD1	A1-06	2A CL LOCA	PRZ pressurization/depressurization	PRZ and Surgeline
				Mass inventory variation	
				PRZ discharge	
				Core heat exchange related phenomena	Core
				PS mass distribution and depressurization	RCS
				Core related phenomena (refilling, flooding, quenching,...)	Core
2	A2-81	CL SBLOCA	SG pressurization/depressurization	SG SS	
			Mass inventory variation	SG SS and PS interface	
			PS-SS heat exchange	Core	
			Core heat exchange related phenomena	RCS (Core, RPV, U-tubes, Legs)	
3	LOBI MOD2	A1-83	0.1 A CL LOCA	Core heat exchange related phenomena	Core
				PS mass distribution and depressurization	RCS
				Core related phenomena (refilling, flooding, quenching,...)	Core
4	BT-15-16	Loss of one MFW pump	SG pressurization/depressurization	SG SS	
			Mass inventory variation	SG SS and PS interface	
			PS-SS heat exchange	PRZ and Surgeline	
			PRZ pressurization/depressurization	PRZ and Surgeline	
			Mass inventory variation	PRZ and Surgeline	
				PRZ discharge	PRZ and Surgeline
				Core heat exchange related phenomena	Core (high pressure conditions)
5	PSB-WVER	Test #03	Stuck open PRZSV	PS-SS heat exchange	SG SS and PS interface
				PRZ pressurization/depressurization	PRZ and Surgeline
				Mass inventory variation	PRZ and Surgeline
				PRZ discharge	PRZ and Surgeline
				Natural circulation occurrence	RCS (Core, RPV, U-tubes, Legs)
6	Test #05	MSLB and SGTR	SG pressurization/depressurization	SG SS	
			Mass inventory variation	SG SS and PS interface	
			PS-SS heat exchange	PRZ and Surgeline	
			PRZ pressurization/depressurization	PRZ and Surgeline	
			Mass inventory variation	PRZ and Surgeline	
				PRZ discharge	PRZ and Surgeline
				PS mass distribution and depressurization	Reactor Coolant System
				Natural circulation occurrence	RCS (Core, RPV, U-tubes, Legs)
7	UPTF	Test 05 run63	End of blowdown and refill phases following a LOCA with CL break	PS mass distribution and depressurization	Reactor Coolant System
8	LOFT	L2-5	2A CL LOCA	Core related phenomena (refilling, flooding, quenching,...)	Core
				Core heat exchange related phenomena	Core and fuel rods
				PS mass distribution and depressurization	Reactor Coolant System
				Core related phenomena (refilling, flooding, quenching,...)	Core
9	SPES	SB-04	200 cm ² CL LOCA	PS-SS heat exchange	SG SS and PS interface
				Core heat exchange related phenomena	Core
				PS mass distribution and depressurization	Reactor Coolant System
				Core related phenomena (refilling, flooding, quenching,...)	Core
				Natural circulation occurrence	RCS (Core, RPV, U-tubes, Legs)


- LOBI MOD2 Test A1.83 – Atucha-II Kv Scaled Calculation




a) UP pressure (Exp, Post, Kv)




b) PS mass (Exp, Post, Kv)




c) Rod temperature at level 8 (Exp, Post, Kv)




d) UP pressure (Exp, Kv, Kv-m)




e) PS mass (Exp, Kv, Kv-m)




f) Rod temperature at level 8 (Exp, Kv, Kv-m)



g) UP pressure (Exp, Kv, Kv-s)







h) PS mass (Exp, Kv, Kv-s)







i) Rod temperature at level 8 (Exp, Kv, Kv-m)

- The Turbine Trip - Closure of Stop Valve - Scenario (AOO, CSA, FSAR Ch. 15.2.3)
 - 60 channels Relap5/3D © nodalization coupled with I&C-AT2 Dynetz nodalization
- Acceptance criteria
 - No fuel melting is acceptable
 - No departure from nucleate boiling can occur in the fuel channels or cladding
 - temperature can not stay above 600°C longer than 120 seconds
 - RCS pressure shall stay below 110% of design pressure (pressurizer safety valves can not be challenged)
 - Secondary side pressure shall stay below 110% of design pressure




Reactor Status		Case A and Case B
Power		100%
Moderator tank average temperature		Nominal (170°C)
Core condition		Equilibrium (BEQ)
I&C Status	Case A	Case B
Single Failure	all systems in working order	Not Relevant
Repair Case		Not Relevant
Emergency Power Mode		No
Consequential Failure		No
Control System Failure		MS max pressure control
Limitation System Failure		No
Reactor Trip	First signal	First signal if it does not occur in Case A and second signal if occurs in Case A
Operator action demanded	-	No, until plant is stabilized in a safe condition






- The Control Rod Ejection Scenario (DBA, CSA, FSAR Ch. 15.4.7)
 - 280 channels Relap5/3D @ nodalization coupled NESTLE
 - Case A: turbine bypass system behavior from 60 channels/Dynetz coupled nodalization
 - Two different Uncertainty evaluation Approaches (CIAU-TN & GRS-SUSA)
- Acceptance criteria
 - Average fuel hot spot enthalpy should be less than 230 cal/g for irradiated fuel
 - Cladding Temperature < 1200 °C
 - RCS pressure shall stay below 120% of design pressure
 - Secondary side pressure shall stay below 120% of design pressure

Reactor Status		Case A and Case B	
Power		100%	
Moderator tank average temperature		Nominal (170°C)	
Core condition		Equilibrium (BEQ)	
I&C Status	Case A	Case B	
Single Failure	Not relevant	Two way valve of KBA-40 spraying	
Repair Case	Not relevant	One KBA-80 Pump	
Emergency Power Mode	No	Yes	
Consequential Failure	No	Stuck rod No 6	
Control System Failure	No	No	
Limitation System Failure	No	No	
Reactor Trip	No failure of the first signal	Failure of the first signal	
Operator action demanded	No, until plant is stabilized in a safe condition		






d) Radial peaking factors at power peak instant (half surface).








- The Double Ended Guillotine Break LOCA (2A-LOCA) in Cold Leg (SBDBA, CSA/RCA/CBA, FSAR Ch. 15.6.5.2.3.1)
 - Different break sizes (0.1A-2A), location and opening time investigated
 - Main objective: TPP, PCT, PCP, JND and JDJ performance





- Main computational tools (EM/CSA)
 - 280-ch (and 451-10nk): first few seconds of the transient with the highest detail allowed by the computational tools. Reactor power → 60-ch nodalization
 - 60-ch\ I&C-AT2 Dynetz: transient evolution and system performances
 - Moderator tank and Boron Lances: boron diffusion (Ansys-CFX)
 - Containment: RELAP (and Melcor) nodalization







CFD to fictitious MT







- EM/CBA → TRANSURANUS (451 calculations), BIC from 280\451 channels calculations
- EM/RCA → MCNP-Origen, 60chan(transport of FP), CONT-R, MACCS2



- BEPU approach for the Chapter 15 of FSAR presented – Atucha-II PHWR
- To adopt and to prove (to the regulatory authority) an adequate quality for the computational tools
 - Selection of PIE
 - Several computer codes and nodalization (including I&C, 3DNK, CFD)
 - Coupling and interconnection among the codes
 - Specific issues coming from the specific design of Atucha-II
 - Qualification process (SCCRED)
- To account for the uncertainty
 - CIAU and CIAU-TN
- Seven years of activity involving more than 30 scientists and recognized international experts
 - Atucha-II licensed by ARN on May 29, 2014
 - **First criticality on June 3, 2014**